

SKG-IKOB PRODUCTCERTIFICATE

437.172.01

Date of issue: 29-09-2016



Certificate holder

Wilka Schließtechnik GmbH
Mettmanner Straße 56-64
D-42549 Velbert
T: +49 (0) 2051 208 10
E: info@wilka.de
I: www.wilka.de



Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

additional cylinder mortice lock

delivered under logo / brand:

WILKA / DLC / MARENCO

delivered under type- and / or article number:

1739

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a series of loops and a long horizontal stroke extending to the right.

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

SKG-IKOB PRODUCTCERTIFICATE

Wilka Schließtechnik GmbH
Number: 437.172.01

page 2 of 2

1. PRODUCT

additional cylinder mortice lock

MAIN GROUP

single lock

2. TECHNICAL SPECIFICATION:

Construction: 1 forend with lockcase with square bolt

Operating / System: with 17 mm profile cylinder; BS: 25 to 45 mm

Material: forend: inox, lockcase: steel zinc coated

Dimension: lockcase: 112xBS+15x15 mm; forend: 180x24x3 mm

Fixing: forend: 2 point

Intended use: metal, door-inward-opening, door-outward-opening
for left or right opening metal doors

3. DELIVERY

The delivery includes an installation instruction:
70 40 505 9.16

4. PERFORMANCES

A additional cylinder mortice lock according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this additional cylinder mortice lock is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled. Remark: In façade elements in accordance with a burglar resistance class (RC) of EN 1627 only SKG*** cylinders are applicable.

A window or door, in existing buildings, in which this additional cylinder mortice lock is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
-